

§ 95.05–15

in cases where a cargo is normally accessible and is considered to be a part of the working or living quarters.

(3) Spaces “specially suitable for vehicles” must be fitted with an approved carbon dioxide system. Alternately, the Commandant may permit the installation of an approved water sprinkler system or other suitable system.

(c) On vessels other than motorboats, a fixed carbon dioxide or other approved system must be installed in all lamp and paint lockers, oil rooms, and similar spaces.

(d) On vessels of 1,000 gross tons and over, contracted for on or after November 19, 1952, or where conversion from coal to oil is contracted for on or after November 19, 1952, a fixed carbon dioxide, foam, or water spray system shall be installed in all spaces containing oil fired boilers, either main or auxiliary, or their fuel oil units, valves, or manifolds in the line between the settling tanks and the boilers.

(e) Fire extinguishing systems shall be provided for internal combustion installations in accordance with the following:

(1) If a fixed fire-extinguishing system is installed to protect an internal combustion propelling machinery installation, the system shall be of the carbon dioxide type.

(2) On vessels of 1,000 gross tons and over on an international voyage, the construction or conversion of which is contracted for on or after May 26, 1965, a fixed carbon dioxide system shall be installed in all spaces containing internal combustion or gas turbine main propulsion machinery, auxiliaries with an aggregate power of 1,000 b. hp. or greater, or their fuel oil units, including purifiers, valves, and manifolds.

(3) On vessels, the construction, conversion or automation of which is contracted for on or after July 1, 1968, the systems shall be in accordance with the following:

(i) A fixed carbon dioxide system shall be installed in any space containing machinery using fuel having a flashpoint of less than 110 °F.

(ii) On vessels of 1,000 gross tons and greater, a fixed carbon dioxide or clean agent system as described in 46 CFR subpart 95.16 must be installed in any space that contains internal combustion

46 CFR Ch. I (10–1–13 Edition)

tion or gas turbine main propulsion machinery, or auxiliary machinery with an aggregate power of 1,000 b.h.p. or greater, or the fuel oil units of such machinery, including purifiers, valves, and manifolds.

(f) On vessels contracted for on or after November 19, 1952, where an enclosed ventilating system is installed for electric propulsion motors or generators, a fixed carbon dioxide extinguishing system must be installed in such a system.

[CGFR 65–50, 30 FR 17001, Dec. 30, 1965, as amended by CGFR 66–33, 31 FR 15285, Dec. 6, 1966; CGFR 67–90, 33 FR 1016, Jan. 26, 1968; CGD 95–027, 61 FR 26006, May 23, 1996; USCG–2006–24797, 77 FR 33878, June 7, 2012]

§ 95.05–15 Hand portable fire extinguishers and semiportable fire extinguishing systems.

(a) Approved hand portable fire extinguishers and semiportable fire extinguishing systems shall be installed on all vessels, other than unmanned barges and fishing vessels, as set forth in subpart 95.50.

Subpart 95.10—Fire Main System, Details

§ 95.10–1 Application.

(a) The provisions of this subpart, with the exception of § 95.10–90, shall apply to all fire main installations contracted for on or after May 26, 1965. Installations contracted for prior to May 26, 1965, shall meet the requirements of § 95.10–90.

§ 95.10–5 Fire pumps.

(a) Vessels shall be equipped with independently driven fire pumps in accordance with Table 95.10–5(a).

TABLE 95.10–5(a)

| Gross tons | | Minimum number of pumps | Hose and hydrant size, inches | Nozzle orifice size, inches | Length of hose feet |
|------------|----------|-------------------------|-------------------------------|-----------------------------|---------------------|
| Over | Not over | | | | |
| | 100 | 1 | 1 1/2 | 1 1/2 | 150 |
| 100 | 1,000 | 1 | 1 1/2 | 5/8 | 50 |
| 1,000 | 1,500 | 2 | 1 1/2 | 5/8 | 50 |
| 1,500 | | 2 | 2 1/2 | 2 7/8 | 250 |

¹On vessels of 65 feet in length or less, 3/4-inch hose of good commercial grade together with a commercial garden hose nozzle may be used. The pump may be hand operated and the length of hose shall be sufficient to assure coverage of all parts of the vessel.